

13.08.150 – General terms and conditions

General Service and Multi-Unit Residential Installations (e.g., Apartments, Condominiums)

- A. CUSTOMER, as prescribed by the 2014 edition NATIONAL ELECTRICAL CODE, adopted by the National Fire Protection Association, the NATIONAL ELECTRICAL SAFETY CODE, 2017 edition C2-2017, RULES AND REGULATIONS of SCMEU, and directives of the Public Works Director or designee, shall furnish, install and maintain:
1. Foundation and pad for transformer(s)
 2. Primary line conduit to the PRIMARY VOLTAGE POINT OF CONNECTION (PVPC)
 3. Ground grid as required
 4. Service Entrance
 5. Secondary line conduit and secondary conductors
 6. Vehicle barriers as required
- B. SCMEU, upon receipt of a specified SERVICE ORIGINATION CONNECTION CHARGE (SOCC), will furnish, install, and maintain:
1. Transformer(s), switchgear, circuit protection, ground connections for primary and secondary compartments
 2. Primary cables and connections
 3. Make secondary line connections at transformer and at the service entrance

(2017-M-14 : § 2; 2013-M-54 : § 6; 2003-M-99 : § 1; 1994-M-65 : § 1; 1992-M-71 : § 1; 1991-M-24 : § 1; 1990-M-36 : § 1; 1989-M-57 : § 1; 1988-M-19 : § 1; 1976-M-25 : § 1; 1976-M-18 : § 1; 1975-M-1 : § 1; 1973-M-1 : § 3; 1972-M-42 : § 1; Prior code : § 14.105(16))