

13.12.430 Local limits

13.12.430 – Local limits

The following pollutant limits are established to protect against pass through and interference. No person shall discharge wastewater containing pollutants in excess of the following:

62.0	mg/L	Ammonia
0.69	mg/L	Arsenic
2.00	mg/L	Barium
574	mg/L	CBOD
0.85	mg/L	Cadmium
0.50	mg/L	Chromium (hex)
3.00	mg/L	Chromium
1.00	mg/L	Chromium (tri)
1000	mg/L	COD
1.00	mg/L	Copper
0.50	mg/L	Cyanide
123	mg/L	FOG
45.0	mg/L	Fluoride
3.00	mg/L	Iron (dissolved)
32.0	mg/L	Iron
0.50	mg/L	Lead
4.00	mg/L	Manganese
0.0005	mg/L	Mercury
3.00	mg/L	Nickel
0.80	mg/L	Phenols
1.00	mg/L	Selenium
0.20	mg/L	Silver
3500	mg/L	Total Dissolved Solids
540	mg/L	Total Suspended Solids
7.50	mg/L	Zinc

The above limits apply at the point where the wastewater is discharged to the POTW. All concentrations for metallic substances are for "total" metal unless indicated otherwise. The Director of Public Works may impose mass limitations in addition to, or in place of, the concentration based limitations above.

(1996-M-72 : § 1)