

13.16.055 â Repair and testing of residential backflow prevention devices

13.16.055 – Repair and testing of residential backflow prevention devices

No residential dual check valve backflow prevention device shall be repaired or tested except by the city. Dual check valve devices damaged or rendered inoperable, due to freezing or abuse, may be replaced or repaired only by the city with the expense to the city, provided no more than one such repair or replacement may be made at city expense. If more than one such repair or replacement is needed, it shall be at the customer's expense.

(2006-M-79 : § 1; 1988-M-61 : § 1)