

13.16.130 â Service pipes - Shutoff valves

13.16.130 – Service pipes - Shutoff valves

Shutoff valves or curb stops shall be placed on every domestic service pipe, and shall be located between the curb line and the sidewalk line where practical, as determined by the City, but not located in driveways. Such boxes shall be so located that they are easily accessible and shall be protected from frost. Individual service lines shall be installed at locations which require a unique fire suppression service line in addition to the domestic water service line. All domestic and fire suppression service lines shall have shutoff valves installed in accordance with the City of St. Charles Engineering Design and Inspection Policy Manual.

(2013-M-15 : § 2; 2007-M-83 : § 1; 1997-M-100 : § 1; Prior code : § 15.205)