

9.05.080 Audible alarm system requirements

9.05.080 – Audible alarm system requirements

An alarm system that emits an audible signal that may be heard by persons outside the protected premises, structure or facility shall conform to the following requirements:

- A. No audible alarm system shall create a sound similar to that of the city's Civil Defense Warning System.
- B. Audible alarm systems shall automatically discontinue emitting an audible alarm within 10 minutes after it is activated.
- C. With respect to systems in existence prior to March 1, 1996, the owner or operator thereof shall have until May 31, 1996, to effect the necessary modifications to comply with the requirements in this chapter.