


**City of St. Charles, Illinois**

**Ordinance No. 1997-M-135**

**An Ordinance Amending Title 13, "Public Utilities," Chapter 13.12,  
"Sewers," of the St. Charles Municipal Code**

**Adopted by the  
City Council  
of the  
City of St. Charles  
December 15, 1997**

**Published in pamphlet form by  
authority of the City Council  
of the city of St. Charles,  
Kane and Du Page Counties,  
Illinois, December 19, 1997**

  
\_\_\_\_\_  
**City Clerk**



DATE OF PUBLICATION 12/17/97  
NEWSPAPER *Camphlet Form*

REFER TO:  
MINUTES 12/15/97  
PAGE \_\_\_\_\_

ORDINANCE NO. 1997-M- 135

AN ORDINANCE AMENDING TITLE 13, "PUBLIC UTILITIES" CHAPTER  
13.12 "SEWERS," OF THE ST. CHARLES MUNICIPAL CODE--  
BE IT ORDAINED BY THE CITY COUNCIL OF THE CITY OF ST. CHARLES,  
KANE AND DUPAGE COUNTIES, ILLINOIS, AS FOLLOWS:

1. THAT TITLE 13, "Public Utilities," Chapter 13.12 "Sewers" of the St. Charles Municipal Code be and is hereby amended by inserting the following Section 13.12.201 "Overhead Sanitary Sewers":

**"13.12.201 Overhead Sanitary Sewers**

- A. All building sewers shall be overhead sewers, and are required where the subdivision's preliminary plan was approved after the effective date of this Chapter. No building sewers shall be laid parallel to or within three feet (3') of any bearing wall which might thereby be weakened. The depth shall be sufficient to afford protection from frost. The building sewer shall be laid at uniform grade in a straight alignment insofar as possible. Changes in direction shall be made only with properly curved pipe and fittings.
- B. An overhead sewer shall be required to be constructed in the lowest level of all new structures where the lowest level is three feet below the elevation of the crown of the street adjacent to the structure when such structures contain a toilet or shower facility within the lowest level.

Plumbing fixtures to be served by an overhead sewer shall drain into an ejection pit with pump and tight seal lid which meets the requirements of the Illinois State Plumbing Code. The ejector pit shall be properly sealed, vented and located to receive sewage by gravity flow from which the liquid shall be lifted and discharged into the sanitary sewer service. The discharge size of the pump shall be a minimum of two inches, and discharge line shall be quipped with a backwater checkvalve, and ball valve. Plumbing fixtures above the aforesaid elevation shall drain entirely by gravity and shall not be drained through the ejection pit.

- C. Where an overhead sanitary sewer system is not required by this Section, a threaded floor drain and plug shall be required to be constructed in the basement of any structure with a level lower than three feet below the elevation of the crown of the street adjacent to the residence.
- D. Where an overhead sanitary sewer system is not required by this Section, a manual shutoff valve will be required for all utility tubs which are installed in the basement of any structure with a level lower than three feet below the elevation of the crown of the adjacent street.

2. That after the adoption and approval hereof, this Ordinance shall (a) be printed or published in book or pamphlet form, published by the authority of the City Council, or (b) within thirty (30) days after the adoption and approval hereof, be published in a newspaper published in and with a general circulation within the City of St. Charles.

PRESENTED to the City Council of the City of St. Charles, Illinois, this 15th day of December, 1997.,

PASSED BY THE City Council of the City of St. Charles, Illinois, this 15th day of December, 1997.

APPROVED by the Mayor of the City of St. Charles, Illinois, this 15th day of December, 1997.

  
MAYOR

ATTEST:

  
CITY CLERK

Council Vote:  
Ayes: 11  
Nays: 0  
Absent: 1

State of Illinois )  
 )  
 ) ss.  
Counties of Kane and DuPage )

## Certificate

I, KRISTIE A. DARULA, certify that I am the duly elected and acting municipal clerk of the city of St. Charles, Kane and DuPage Counties, Illinois.


I further certify that on December 15, 1997, the Corporate Authorities of such municipality passed and approved Ordinance No. 1997-M-135, entitled

"An Ordinance Amending Title 13, "Public Utilities,"  
Chapter 13.12, "Sewers," of the St. Charles Municipal Code",

which provided by its terms that it should be published in pamphlet form.

The pamphlet form of Ordinance No. 1997-M-135, including the Ordinance and a cover sheet thereof was prepared, and a copy of such Ordinance was posted in the municipal building, commencing on December 19, 1997, and continuing for at least ten days thereafter. Copies of such Ordinance were also available for public inspection upon request in the office of the municipal clerk.

DATED at St. Charles, Illinois, this 17<sup>th</sup> day of December, 1997.

  
\_\_\_\_\_  
Municipal Clerk

